

Summary of Lead in Drinking Water Results for Ludlow Elementary School¹

Sample Location	First-Draw Result ² ppb	Flush Result ³ ppb
Armory Kitchen Sink	1	<1
Gym Bottle Filler	<1	
Gym Bottle Fountain	<1	<1
Kindergarten Sink	3	<1
Kitchen Sink	8	2
Locker Room Bottle Filler	3	
Locker Room Fountain	3	3
Office	<1	<1
Preschool Bottle Filler	<1	
Preschool Fountain	<1	<1
Preschool Sink	1	<1

Notes:

1. The Environmental Protection Agency's action level for lead in public drinking water is 15 parts per billion (ppb). The Vermont Health Advisory for lead in drinking water is 1 ppb.
2. A first draw sample collects the first water to come out of the tap after a period of inactivity, typically 8-18 hours. A high first draw result may indicate that faucets and fixtures are the likely source of lead.
3. A flush sample is taken after running cold water for 30 seconds, which tests water further upstream in the plumbing. A high flush result may indicate that plumbing is the likely source of lead.

January 9, 2018